

Wels, December 14th 2018

COMPLIANCE WITH EN 61724-1 “PHOTOVOLTAIC SYSTEM PERFORMANCE - PART 1. MONITORING”

Fronius International GmbH

hereby confirms that the Fronius inverters

- / **Fronius Primo 3.0-1 – 8.2-1**
- / **Fronius Symo 3.0-3-S – 4.5-3-S**
- / **Fronius Symo 3.0-3-M – 20.0-3-M**
- / **Fronius Eco 25.0 – 27.0**

fulfil the Class B requirements according to EN 61724-1 “Photovoltaic System Performance - Part 1. Monitoring”, for the electrical measurement uncertainties (table 10) and sampling and recording intervals (table 2).

Fronius International GmbH
Business Unit Solar Energy
Froniusplatz 1
A-4600 Wels

A handwritten signature in blue ink, appearing to read "Martin Heidl".

DI Dr. Martin Heidl
Head of Systems Technology