

ETNY8-6098926 DDC-100A2P

Catalog Number: ETNY8-6098926 DDC-100A2P

Maxima DDC DC switch disconnecter, 100 A, 2 pole, 2 N/O, 2 N/C, with grey knob, service distribution board mounting

Especificaciones generales



| | |
|---|--|
| Product Name | Catalog Number |
| Maxima DDC Insulated enclosure | 609ETNY8-6098926 DDC-100A2P8926 |
| EAN | Product Length/Depth |
| 8711426533226 | 132 mm |
| Product Height | Product Width |
| 97 mm | 90 mm |
| Product Weight | Certifications |
| 1.5 kg | IEC/EN 60947-3 IEC/EN 60204 RoHS IEC/EN 60947 CE VDE 0660 |
| Catalog Notes | Model Code |
| Rated Short-time Withstand Current (Icw) for a time of 1 second | DDC-100/2 |

Características y Funciones

Actuator color

Gray

Actuator type

Long turning handle

Features

Version as main switch

Version as maintenance-/service switch

Fitted with:

Gray knob

Functions

Interlockable

Number of poles

Two-pole

General

Accessories

Auxiliary contact fitted by user.

Degree of protection

NEMA Other

Degree of protection (front side)

IP20

Lifespan, mechanical

10,000 Operations

Mounting method

Service distribution board mounting

Mounting position

As required

Overvoltage category

III

Pollution degree

3

Product Category

DC switch-disconnector

Main switch

Rated impulse withstand voltage (Uimp)

8000 V

Suitable for

Ground mounting

Condiciones climáticas ambientales

Ambient operating temperature - min

-25 °C

Ambient operating temperature - max

55 °C

Ambient storage temperature - min

-30 °C

Ambient storage temperature - max

80 °C

Secciones de conexión

Terminal capacity

6 - 35 mm², solid

6 - 25 mm², flexible

Stripping length (main cable)

15 mm

Tightening torque

3 Nm, Screw terminals

Especificaciones eléctricas

Rated operational current (I_e) at DC-21B, 1000 V
100 A

Rated operational current (I_e) at DC-21B, 480 V
100 A

Rated operational current (I_e) at DC-21B, 600 V
100 A

Rated operational power at AC-23A, 400 V, 50 Hz
0 kW

Rated operational power at AC-3, 380/400 V, 50 Hz
0 kW

Rated operational voltage (U_e) at AC - max
1000 V

Rated uninterrupted current (I_u)
100 A

Uninterrupted current

Rated uninterrupted current I_u is specified for max. cross-section.

Rated insulation voltage (U_i)
1100 V

Clasificación de cortocircuito

Rated conditional short-circuit current (I_q)
0 kA

Rated short-circuit making capacity (I_{cm})
4.3 kA_{eff}

Rated short-time withstand current (I_{cw})
3 kA, Contacts, 1 second
3 kA

Contactos

Number of auxiliary contacts (change-over contacts)
0

Number of auxiliary contacts (normally closed contacts)
2

Number of auxiliary contacts (normally open contacts)
2

Verificación del diseño

Equipment heat dissipation, current-dependent P_{vid}
6 W

Heat dissipation capacity P_{diss}
0 W

Heat dissipation per pole, current-dependent P_{vid}
6 W

Rated operational current for specified heat dissipation (I_n)
100 A

Static heat dissipation, non-current-dependent P_{vs}
0 W

10.2.2 Corrosion resistance

Meets the product standard's requirements.

10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

10.2.3.2 Verification of resistance of insulating materials to normal heat

Meets the product standard's requirements.

10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects

Meets the product standard's requirements.

10.2.4 Resistance to ultra-violet (UV) radiation

Meets the product standard's requirements.

10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

10.2.7 Inscriptions

Meets the product standard's requirements.

10.3 Degree of protection of assemblies

Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances

Meets the product standard's requirements.

10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

10.8 Connections for external conductors

Is the panel builder's responsibility.

10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

10.9.4 Testing of enclosures made of insulating material

Is the panel builder's responsibility.

10.10 Temperature rise

The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating

Recursos

Catálogos

[Product Range Catalog Industrial switch-disconnectors](#)

Dibujos

[Maxima-rotary-switches-ddc-insulated-enclosure-dimensions-007.eps](#)

[Maxima-general-rotary-switch-t0-step-switch-symbol-005.eps](#)

[Maxima-rotary-switches-ddc-insulated-enclosure-3d-drawing.eps](#)

eCAD model

[DA-CE-ETN.DDC-100_2](#)

Informes de certificación

[DA-DC-00003811.pdf](#)

[DA-DC-00004006.pdf](#)

Instrucciones de montaje

[IL008021ZU](#)

mCAD model

[DA-CS-ddc_100_2](#)

[DA-CD-ddc_100_2](#)

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.